


PROPOSED WATERMAIN CONNECTION TO EXISTING 300mm AC WATERMAIN ON CORK ROAD



**Health and Safety:**  
THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS, THE SPECIFICATION AND THE SAFETY AND HEALTH PLAN.  
THE APPOINTMENT OF THE PROJECT SUPERVISOR DESIGN PROCESS IS THE CLIENT'S RESPONSIBILITY.  
TEMPORARY WORKS PROPOSALS AND/OR METHOD STATEMENTS TO BE SUBMITTED TO THE PSDP AND THE PSCS FOR WORKS WHICH INVOLVE PARTICULAR RISKS.

- Notes:**
- NO PART OF THIS DRAWING MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF MALONE O'REGAN CONSULTING ENGINEERS AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DRAWING WAS ORIGINALLY ISSUED.
  - THE APPOINTMENT OF THE PROJECT SUPERVISOR DESIGN PROCESS IS THE CLIENT'S RESPONSIBILITY.
  - ALL DIMENSIONS IN mm UNLESS NOTED OTHERWISE.
  - THE CONTRACTOR SHALL CHECK ALL DIMENSIONS PRIOR TO COMMENCEMENT OF CONSTRUCTION. DISCREPANCIES SHALL BE REPORTED TO THIS OFFICE IN WRITING.
  - THIS DRAWING TO BE READ IN ACCORDANCE WITH ALL RELEVANT ENGINEERS' DRAWINGS AND SPECIFICATIONS.

**WATERMAIN - LEGEND**

PROPOSED 150mm Ø HPPE PE 100 SDR-17 WATERMAIN

EXISTING WATERMAIN

PROPOSED HYDRANT

PROPOSED SLUICE VALVE

PROPOSED AIR VALVE

PROPOSED WATER METER

THRUST BLOCK

EXISTING HYDRANT

EXISTING SLUICE VALVE

EXISTING AIR VALVE

EXISTING WATER METER

ALL JOINTS TO BE WELDED JOINTS. ALL WATER SUPPLY, DRAINAGE & WATERMAIN DETAILS TO BE IN STRICT COMPLIANCE WITH 'IRISH WATER - CODE OF PRACTICE FOR WATER INFRASTRUCTURE' & 'IRISH WATER - STANDARD DETAILS FOR WATER AND WASTEWATER NETWORKS'

Meters for individual units will be installed internally within the Premises in accordance with the Building Control Authority's requirements and subject to approval by Irish Water.

P1	PLANNING APPLICATION	19.02.'24	GL	CC	COB
P	PLANNING APPLICATION	20.09.'23	GL	JK	COB
Rev.	Description	Date	Drawn	Chkd	Appr

THIS DRAWING TO BE USED FOR PLANNING PURPOSES ONLY

**ADR**  
MALONE O'REGAN  
CONSULTING ENGINEERS

3-4 Canada Street  
Waterford  
Co. Waterford.  
X91 V52K

Tel: +353 51 876 855  
Email: waterford@moroe.ie  
Web: www.maloneoregan.com

Offices also in:  
DUBLIN : Tel: +353 1 260 2655 Email: dublin@moroe.ie  
GALWAY: Tel: +353 91 531 069 Email: galway@moroe.ie  
LONDON: Tel: +44 208 5281685 Email: london@moroe.ie

Client: **NOEL FRISBY CONSTRUCTION LTD.**

Job: **STUDENT ACCOMMODATION AT CORK ROAD, WATERFORD.**

Drawing: **GENERAL ARRANGEMENT – WATERMAIN LAYOUT**

Job No	Drw No	Stage	Revision	Scale
W22076	P852	PL	P1	A1 1:500 A3 1:1,000